

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7320-1591:211

Page 1 of 1

CATEGORY: Speakers

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

DESIGN: Models G4-S2, G4R-S2, G4-S7, G4R-S7, G4F-S7, G4RF-S7, G4F-S2, G4RF-S2, *GC-S2, *GCF-S2, *GC-S7, and *GCF-S7 speakers.
Models G4-S2VM, G4R-S2VM, G4-S7VM, G4R-S7VM, G4F-S2VM, G4RF-S2VM, G4F-S7VM, G4RF-S7VM, *GC-S2VM, *GCF-S2VM, *GC-S7VM, and *GCF-S7VM speaker strobes.
Models G4B and G4RB speaker enclosure backbox. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 25 Vrms or 70 Vrms
¼ W, ½ W, 1 W, 2 W
Candela: 15cd, 30cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control unit. Speakers with a strobe are suitable for the hearing impaired. For indoor use only. *Models G4-S2VM, G4R-S2VM, G4-S7VM, G4R-S7VM, G4F-S2VM, G4RF-S2VM, G4F-S7VM, G4RF-S7VM, GC-S2VM, GCF-S2VM, GC-S7VM and GCF-S7VM are intended to be used with models G1M-RM (CSFM Listing No. 7320-1591:201), and SIGA-CC1S and SIGA-MCC1S (CSFM Listing No. 7300-1591:121) sync modules.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7320-1388:243

*Rev. 06-26-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 26, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**